

Issues

Estimated time: 88.0 Spent time: 0.0

#	Project	Tracker	Status	Priority	Subject	Assignee	Total estimated time	Total spent time	Updated
6672	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Create User's manual.	Sermsak Prowee	16.00	0.00	18 Feb 2026 13:38
6562	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix PLC program about Exhaust Zone Office and Exhaust Zone Solder cannot be opened through a web browser.	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6561	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix PLC program about Discharge Pressure, Oil Separator Pressure and Line Pressure of Air Compressor	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6560	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fixes Exhaust Zone Air Compressor's operation while the device is turned on in manual mode.	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6559	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix PLC program about Air Compressor	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6558	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix PLC program about Air Compressor and Air flow	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6557	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix Communication Command of PROTOCOL STUDIO on port1	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6556	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix PLC program about Air Compressor and Inverter	Sermsak Prowee	8.00	0.00	11 Feb 2026 10:48
6555	THAI ASAHI DENSO CO., LTD.	Project progress work	Closed	Normal	[Coding] Fix Modbus's data of Air Compressor	Sermsak Prowee	16.00	0.00	11 Feb 2026 10:47