

ADVICS Manufacturing(Thailand)Co.,Ltd. - Project progress work #200

Parent project # 566 (Closed): [PJ230037]MT MOC Loss analysis system add function for ADVICS

Counter RH fuction not operation

06 Nov 2023 08:20 - Santi Srichankaew

Status:	Closed	Start date:	04 Nov 2023
Priority:	Normal	Due date:	04 Nov 2023
Assignee:	Santi Srichankaew	% Done:	100%
Category:		Estimated time:	8.00 hours
Target version:		Spent time:	8.00 hours
Finish date:	15 Nov 2023	DB skills:	
Programming skills:		OS skills:	
Description			
Problem			
-output PLC HARU machine not send signal.			
Action			
-check signal ladder plc haru machine found ladder wrong operation.			
-Edit program PLC haru machine detect sensor.counter.			
Cause			
-Programmer haru wrong ladder operation.			
Result			
-Counter RH normal running.			

History

#1 - 15 Nov 2023 16:09 - Santi Srichankaew

- Status changed from New to Confirmation request
- % Done changed from 90 to 100
- Finish date set to 15 Nov 2023

Issue
Counter RH fuction not operation

Status
Complate

#2 - 15 Nov 2023 17:41 - Kittisak Isarapongporn

- Status changed from Confirmation request to Close request

#3 - 19 Nov 2023 09:57 - Ryo Nozaki

- Project changed from ADVICS Manufacturing(Thailand)Co.,Ltd. to 36
- Status changed from Close request to Closed

#4 - 04 May 2024 16:17 - Ryo Nozaki

- Project changed from 36 to ADVICS Manufacturing(Thailand)Co.,Ltd.
- Parent task set to #566